

# Fire-resistance test on fire collars protecting a concrete slab penetrated by services

## Test Report

**Author:** Chris Wojcik  
**Report number:** FSP 1692  
**Date:** 14 June 2017

**Client:** Snap Fire Systems Pty Ltd

Commercial-in-confidence

### Inquiries should be address to:

Fire Testing and Assessments  
Infrastructure Technologies  
14 Julius Avenue  
North Ryde, NSW 2113  
Telephone +61 2 9490 5444




Author  
Infrastructure Technologies  
14 Julius Avenue  
North Ryde, NSW 2113  
Telephone +61 2 9490 5500

The Client  
Snap Fire Systems Pty Ltd  
Unit 2/160 Redland Bay Road  
Capalaba QLD  
Telephone +61 7 3245 2133

### Report Status and Revision History:

VERSION	STATUS	DATE	DISTRIBUTION	ISSUE NUMBER
Revision A	Draft for review	16/07/2015	CSIRO/SNAP	FSP 1692
Revision B	Final for issue	26/10/2015	CSIRO/SNAP	FSP 1692
Revision C	Amend / re-issue	14/06/2017	CSIRO/SNAP	FSP 1692

### Report Authorization:

AUTHOR	REVIEWED BY	AUTHORISED BY
Chris Wojcik	Brett Roddy	Brett Roddy
		
14 June 2017	14 June 2017	14 June 2017

## Use of this Report

### **Use of Reports – Testing**

*This report is subject to binding obligations under which it was prepared. In particular, the Report must not be used:*

- *as a means of endorsement; or*
- *in a company prospectus or notification to a Stock Exchange document for capital raising, without the prior written consent of CSIRO.*

*The Report may be published verbatim and in full, provided that a statement is included on the publication that it is a copy of the Report issued by CSIRO.*

*Excerpts of the Report may not be published.*

### **Use of Reports – Consultancy**

*This report is subject to binding obligations under which it was prepared. In particular, the Report may only be used for the following purposes:*

- *the information in the Report may be used by the party that commissioned the Report for its internal business operations (but not licensing to third parties);*
- *the report may be copied for distribution within the organisation that commissioned the Report;*
- *copies of the Report (or extracts of the Report) may be distributed to contractors and agents of the organisation that commissioned the Report who have a need for the Report for its internal business operations. Any extracts of the Report distributed for this purpose must clearly note that the extract is part of a larger Report held by the organisation that commissioned the Report and which has been prepared by CSIRO.*

*The name, trade mark or logo of the CSIRO must not be used without the prior written consent of CSIRO.*

*The Report must not be used as a means of endorsement without the prior written consent of CSIRO.*

## Copyright and disclaimer

© 2017 CSIRO To the extent permitted by law, all rights are reserved and no part of this publication covered by copyright may be reproduced or copied in any form or by any means except with the written permission of CSIRO.

## Important disclaimer

CSIRO advises that the information contained in this publication comprises general statements based on scientific research. The reader is advised and needs to be aware that such information may be incomplete or unable to be used in any specific situation. No reliance or actions must therefore be made on that information without seeking prior expert professional, scientific and technical advice. To the extent permitted by law, CSIRO (including its employees and consultants) excludes all liability to any person for any consequences, including but not limited to all losses, damages, costs, expenses and any other compensation, arising directly or indirectly from using this publication (in part or in whole) and any information or material contained in it.

# Contents

1	Introduction .....	4
1.1	Identification of specimen .....	4
1.2	Sponsor .....	4
1.3	Manufacturer .....	4
1.4	Test standard .....	4
1.5	Reference standard.....	4
1.6	Test number .....	4
1.7	Test date .....	4
2	Description of specimen .....	5
2.1	General.....	5
2.2	Dimensions .....	6
2.3	Orientation.....	6
2.4	Conditioning.....	6
3	Documentation .....	6
4	Equipment.....	6
4.1	Furnace .....	6
4.2	Temperature .....	6
4.3	Measurement system .....	7
5	Ambient temperature .....	7
6	Departure from standard .....	7
7	Termination of test .....	7
8	Test results .....	7
8.1	Critical observations .....	7
8.2	Furnace temperature.....	7
8.3	Furnace severity.....	7
8.4	Specimen temperature .....	8
8.5	Performance .....	8
9	Fire-resistance level (FRL) .....	9
10	Field of direct application of test results .....	9
11	Tested by .....	9
	Appendices .....	10
	Appendix A – Measurement location .....	10
	Appendix B – Photographs.....	11
	Appendix C – Furnace Temperature .....	14
	Appendix D – Installation drawings.....	18
	Appendix E – Specimen Drawings .....	20
	Appendix F – Certificate(s) of Test .....	22
	References .....	24

# Fire-resistance test on fire collars protecting a concrete slab penetrated by services

## Sponsored Investigation No. FSP 1692

## 1 Introduction

### 1.1 Identification of specimen

The sponsor identified the specimen as Snap Cast-in Fire Collars protecting a 150-mm thick concrete slab penetrated by two (2) stack pipes and one (1) floor waste.

### 1.2 Sponsor

Snap Fire Systems Pty Ltd  
Unit 2/160 Redland Bay Road  
CAPALABA QLD

### 1.3 Manufacturer

Snap Fire Systems Pty Ltd  
Unit 2/160 Redland Bay Road  
CAPALABA QLD

### 1.4 Test standard

Australian Standard 1530, Methods for fire tests on building materials, components and structures, Part 4-2005, Fire-resistance tests of elements of construction.

### 1.5 Reference standard

Australian Standard 4072, Components for the protection of openings in fire-resistant separating elements, Part 1 - 2005, Service penetrations and control joints.

### 1.6 Test number

CSIRO Reference test number: FS 4473/3837

### 1.7 Test date

The fire-resistance test was conducted on 9 February 2015.

## 2 Description of specimen

### 2.1 General

The specimen comprised an 1150-mm x 1150-mm x 150-mm thick reinforced concrete slab penetrated by two (2) stack pipes and one (1) floor waste protected by retrofit Snap Fire System fire collars. The pipes are stated to be manufactured in accordance with AS/NZS 1260: 2009 'PVC-U pipes and fittings for drain, waste and vent application' and AS/NZS 5065: 2005 'Polyethylene and polypropylene pipes and fittings for drainage and sewerage applications'.

For the purpose of the test, the specimens were referenced as Penetrations 1, 2 and 3. Two (2) specimen are included in this report (Penetration 2 and 3).

#### Penetration 2 – LP100R retrofitted fire collar protecting a 110-mm diameter Polyvinyl Chloride (PVC-SC) pipe incorporating a floor waste

The SNAP LP100R retrofitted fire collar comprised a 0.95-mm steel casing with a 118-mm inner diameter and a 257-mm diameter base flange. The 62-mm high collar casing incorporated a 400-mm x 57-mm x 6-mm thick intumescent material. The closing mechanism comprised three stainless steel springs, nylon fuse links and a 415-mm x 120-mm stainless steel mesh, as shown in drawing numbered LP100R-T, dated 4 November 2014, by SNAP Fire Systems. The collar was fixed to the underside of the slab with 6.5-mm Zinc Hex Head Sleeve Anchors as shown in drawing titled "Test Slab S-15-C Penetration #2 110-mm SC-PVC Pipe w Fitting + LP100R on Floor Waste", dated 18 May 2015, by Snap Fire Systems Pty Ltd.

The penetrating service comprised a 110-mm OD PVC sandwich construction pipe, with a wall thickness of 1.6-mm fitted through the LP 100 R Snap fire collars. The floor waste system was fitted with a chromed brass floor waste grate. A 35-mm thick cement screed was laid on top of the concrete slab and finished flush with the floor grate. On the exposed side of the slab, a nominal 100-mm OD PVC gully trap was connected to the penetrating pipe, supported by an M10 HKD clamp fixed to the concrete slab. On the exposed face, the gully trap was capped using a PVC end cap.

The floor waste gully was charged with water to the level shown in drawing titled "Test Slab S-15-C Penetration #2 110-mm SC-PVC Pipe w Fitting + LP100R on Floor Waste", dated 18 May 2015, by Snap Fire Systems Pty Ltd.

#### Penetration # 3 – HP250 R retrofitted fire collar protecting a 250-mm diameter High Density Polyethylene (HDPE) stack pipe

The SNAP retrofitted HP250 R collar comprised a 0.95-mm steel casing with a 279-mm inner diameter and a 460-mm diameter base flange. The 184-mm high collar casing incorporated two strips of Intumesh intumescent material, 910-mm x 179-mm x 12-mm thick and 958-mm x 179-mm x 2.5-mm thick. The closing mechanism comprised five stainless steel springs, with nylon fuse links, and a 949-mm x 179-mm 304 stainless steel mesh located in between the intumescent strips as shown in drawing numbered HP 250 R-T dated 7 January 2015, by Snap Fire Systems Pty Ltd.

The penetrating service comprised a 250-mm diameter High Density Polyethylene (HDPE) stack pipe, with a wall thickness of 7.25-mm fitted through the collar's sleeve. The pipe projected vertically, 2000-mm above the concrete slab. The pipe was supported at 500-mm and 1000-mm from the unexposed face of the concrete slab. On the exposed side of the slab, the penetrating pipe was supported by 5 brackets with Steel Wedge Anchors fixed to the concrete slab. On the exposed face, the pipe was capped using a Kaowool plug.

On the unexposed face, the gap between the pipe and the slab was filled with a bead of Fullers Firesound as show in drawing titled "Penetration #3 – HDPE 250-mm stack", dated 13 April 2015, by Snap Fire Systems Pty Ltd.

## 2.2 Dimensions

The overall dimension of the concrete slab was 1150-mm wide x 1150-mm long, to suit the opening in the specimen containing frame.

## 2.3 Orientation

The reinforced concrete slab was placed horizontally on top of the furnace chamber, and subjected to fire exposure from the underside.

## 2.4 Conditioning

The concrete slab was left to cure for a period longer than 30 days.

# 3 Documentation

The following documents were supplied or referenced by the sponsor as a complete description of the specimen and should be read in conjunction with this report:

Drawing titled “Penetration #2 - 110-mm SC-PVC Pipe w fitting + LP100R on floor waste”, dated 18 May 2015, by Snap Fire Systems Pty Ltd.

Drawing titled “Penetration #3 – HDPE 250-mm stack”, dated 13 April 2015, by Snap Fire Systems Pty Ltd.

Drawing numbered HP250R-T, dated 7 January 2015, by Snap Fire Systems Pty Ltd.

Drawing numbered LP100R-T, dated 4 November 2014, by Snap Fire Systems Pty Ltd.

# 4 Equipment

## 4.1 Furnace

The furnace had a nominal opening of 1000-mm x 1000-mm for attachment of vertical or horizontal specimens.

The furnace was lined with refractory bricks and materials with the thermal properties as specified in AS 1530.4-2005 and was heated by combustion of a mixture of natural gas and air.

## 4.2 Temperature

The temperature in the furnace chamber was measured by four type K, 3-mm diameter, and 310 stainless steel Mineral Insulated Metal Sheathed (MIMS) thermocouples. Each thermocouple was housed in high-nickel steel tubes opened at the exposed end.

The temperatures of the specimen were measured by glass-fibre insulated and sheathed K-type thermocouples with a wire diameter of 0.5-mm.

Location of the thermocouples on the unexposed face of the specimen are described in Appendix A.

### 4.3 Measurement system

The primary measurement system comprised a multiple-channel data logger, scanning at one minute intervals during the test.

## 5 Ambient temperature

The temperature of the test area was 21°C at the commencement of the test.

## 6 Departure from standard

There were no departures from the requirements of AS 1530.4-2005.

## 7 Termination of test

The test was terminated at 230 minutes by the agreement with the sponsor.

## 8 Test results

### 8.1 Critical observations

The following observations were made during the fire-resistance test:

Time	Observation
2 minutes -	Smoke is fluing from Penetration # 2 – floor waste.
5 minutes -	Smoke is fluing from Penetration 3.
8 minutes -	Smoke fluing from Penetration # 3 has decreased.
230 minutes -	Flaming is observed on the unexposed face of Penetration # 2. Flames have spread – affecting Penetration # 3. Test terminated.

### 8.2 Furnace temperature

Figure 1 shows the standard curves of temperature versus time for heating the furnace chamber and the actual curves of average and maximum temperature versus time recorded during the heating period.

### 8.3 Furnace severity

Figure 2 shows the curve of furnace severity versus time during the heating period.



## 8.4 Specimen temperature

Figure 3 shows the curve of maximum temperature versus time associated with Penetration 2.

Figure 4 shows the curve of maximum temperature versus time associated with Penetration 3.

## 8.5 Performance

Performance observed in respect of the following AS 1530.4-2005 criteria:

Penetration 2 –LP100R retrofitted fire collar protecting a 110-mm diameter Polyvinyl Chloride (PVC-SC) pipe incorporating a floor waste

Structural adequacy	-	not applicable
---------------------	---	----------------

Integrity	-	no failure at 230 minutes
-----------	---	---------------------------

Insulation	-	no failure at 163 minutes
------------	---	---------------------------

Penetration # 3 – HP250 R retrofitted fire collar protecting a 250-mm diameter High Density Polyethylene (HDPE) stack pipe

Structural adequacy	-	not applicable
---------------------	---	----------------

Integrity	-	no failure at 230 minutes
-----------	---	---------------------------

Insulation	-	no failure at 230 minutes
------------	---	---------------------------

This report details methods of construction, the test conditions and the results obtained when the specific element of construction described herein was tested following the procedure outlined in this standard. Any significant variation with respect to size, constructional details, loads, stresses, edge or end conditions, other than those allowed under the field of direct application in the relevant test method, is not covered by this report.

Because of the nature of fire resistance testing and the consequent difficulty in quantifying the uncertainty of measurement of fire resistance, it is not possible to provide a stated degree of accuracy of the result.

## 9 Fire-resistance level (FRL)

For the purpose of building regulations in Australia, the FRL's of the test specimens were as follows:

Penetration 2      -      -/180/120

Penetration 3      -      -/180/180

For the purposes of AS 1530.4-2005 the results of these fire tests may be used to directly assess fire hazard, but it should be noted that a single test method will not provide a full assessment of fire hazard under all fire conditions.

## 10 Field of direct application of test results

The results of the fire test contained in this test report are directly applicable, without reference to the testing authority, to similar constructions where one or more changes listed in Clause 10.11 of AS 1530.4-2005, have been made provided no individual component is removed or reduced.

## 11 Tested by

Mario Lara-Ledermann  
Testing Officer

# Appendices


## Appendix A – Measurement location

Measurement Location		
Group location	T/C Position	T/C designation
Specimen		
Penetration 1	On slab – 25-mm from the pipe.	S1
	On slab – 25-mm from the pipe.	S2
	On pipe – 25-mm from the slab.	S3
	On pipe – 25-mm from the slab.	S4
Penetration 2	On grate.	S5
	On step – 25-mm from the grate.	S6
	On step – 25-mm from the grate.	S7
Penetration 3	On slab – 25-mm from the pipe.	S8
	On slab – 25-mm from the pipe.	S9
	On pipe – 25-mm from the slab.	S10
	On pipe – 25-mm from the slab.	S11

Appendix B – Photographs



**PHOTOGRAPH 1 – EXPOSED FACE OF SPECIMENS PRIOR TO TESTING**



**PHOTOGRAPH 2 – UNEXPOSED FACE OF SPECIMENS PRIOR TO TESTING**



**PHOTOGRAPH 3 – SPECIMENS AFTER 60 MINUTES OF TESTING**




**PHOTOGRAPH 4 – SPECIMENS AFTER 120 MINUTES OF TESTING**





**PHOTOGRAPH 5 – SPECIMENS AFTER 180 MINUTES OF TESTING**



**PHOTOGRAPH 6 – EXPOSED FACE OF SPECIMENS AT CONCLUSION OF TESTING**

Appendix C – Furnace Temperature





FIGURE 1 – FURNACE TEMPERATURE



**FIGURE 2 – FURNACE SEVERITY**






FIGURE 3 – SPECIMEN TEMPERATURE – ASSOCIATED WITH PENETRATION 2






FIGURE 4 – SPECIMEN TEMPERATURE – ASSOCIATED WITH PENETRATION 3

## Appendix D – Installation drawings




**DRAWING TITLED "TEST SLAB S-15-C PENETRATION #2 110-MM SC-PVC PIPE W FITTING + LP100R ON FLOOR WASTE", DATED 18 MAY 2015, BY SNAP FIRE SYSTEMS PTY LTD.**

PENETRATION # 3  
HDPE 250-MM STACK  
13 APR 2015




DRAWING NUMBERED "PENETRATION #3 – HDPE 250-MM STACK", DATED 13 APRIL 2015, BY SNAP FIRE SYSTEMS PTY LTD.

Appendix E – Specimen Drawings



DRAWING NUMBERED HP 250 R-T DATED 7 JANUARY 2015, BY SNAP FIRE SYSTEMS PTY LTD.



DRAWING NUMBERED LP100R-T, DATED 4 NOVEMBER 2014, BY SNAP FIRE SYSTEMS.



## Appendix F – Certificate(s) of Test

INFRASTRUCTURE TECHNOLOGIES www.csiro.au		
14 Julius Avenue, North Ryde NSW 2113 PO Box 52, North Ryde NSW 1670, Australia T (02) 9490 5444 • ABN 41 687 119 230		
<h3>Certificate of Test</h3>		No. 2948
<p>"Copyright CSIRO 2015 ©" Copying or alteration of this report without written authorisation from CSIRO is forbidden.</p>		
<p>This is to certify that the element of construction described below was tested by the CSIRO Division of Materials Science and Engineering in accordance with Australian Standard 1530, Methods for fire tests on building materials, components and structures, Part 4-2005 on behalf of:</p>		
<p>Snap Fire Systems Pty Ltd Unit 2/160 Redland Bay Road CAPALABA QLD</p>		
<p>A full description of the test specimen and the complete test results are detailed in the Division's Sponsored Investigation report numbered FSP 1692.</p>		
Product Name:	Penetration 2 – LP100R retrofitted fire collar protecting a 110-mm diameter Polyvinyl Chloride (PVC-SC) pipe incorporating a floor waste	
Description:	<p>The SNAP LP100R retrofitted fire collar comprised a 0.95-mm steel casing with an 118-mm inner diameter and a 257-mm diameter base flange. The 62-mm high collar casing incorporated a 400-mm x 57-mm x 6-mm thick intumescent material. The closing mechanism comprised three stainless steel springs, nylon fuse links and a 415-mm x 120-mm stainless steel mesh, as shown in drawing numbered LP100R-T, dated 4 November 2014, by SNAP Fire Systems. The collar was fixed to the underside of the slab with 6.5-mm Zinc Hex Head Sleeve Anchors as shown in drawing titled "Test Slab S-15-C Penetration #2 110-mm SC-PVC Pipe w Fitting + LP100R on Floor Waste", dated 18 May 2015, by Snap Fire Systems Pty Ltd. The penetrating service comprised a 110-mm OD PVC sandwich construction pipe, with a wall thickness of 1.6-mm fitted through the LP 100 R Snap fire collars. The floor waste system was fitted with a chromed brass floor waste grate. A 35-mm thick cement screed was laid on top of the concrete slab and finished flush with the floor grate. On exposed side of the slab, a nominal 100-mm OD PVC gully trap was connected to the penetrating pipe, supported by an M10 HKD clamp fixed to the concrete slab. On the exposed face, the gully trap was capped using a PVC end cap. The floor waste gully was charged with water to the level shown in drawing titled "Test Slab S-15-C Penetration #2 110-mm SC-PVC Pipe w Fitting + LP100R on Floor Waste", dated 18 May 2015, by Snap Fire Systems Pty Ltd.</p>	
Structural Adequacy	not applicable	
Integrity	no failure at 230 minutes	
Insulation	163 minutes	
<p>and therefore for the purpose of Building Regulations in Australia, achieved a fire-resistance level (FRL) of -/180/120. The FRL is applicable for exposure to the fire from the same direction as tested.</p>		
<p>This certificate is provided for general information only and does not comply with regulatory requirements for evidence of compliance.</p>		
Testing Officer:	Mario Lara-Ledermann	Date of Test: 9 February 2015
<p>Issued on the 14<sup>th</sup> day of June 2017 without alterations or additions.</p>		
<p> Brett Roddy Manager, Fire Testing and Assessments</p>		
	<p>This document is issued in accordance with NATA's accreditation requirements. Accreditation No. 165 – Corporate Site No. 3625 Accredited for compliance with ISO/IEC 17025</p>	

COPY OF CERTIFICATE OF TEST – NO. 2948



## Certificate of Test

No. 2656

"Copyright CSIRO 2015 ©"  
 Copying or alteration of this report  
 without written authorisation from CSIRO is forbidden.

This is to certify that the element of construction described below was tested by the CSIRO Division of Materials Science and Engineering in accordance with Australian Standard 1530, Methods for fire tests on building materials, components and structures, Part 4-2005 on behalf of:

Snap Fire Systems Pty Ltd  
 Unit 2/160 Redland Bay Road  
 CAPALABA QLD

A full description of the test specimen and the complete test results are detailed in the Division's Sponsored Investigation report numbered FSP 1692.

Product Name: Penetration # 3 – HP250 R retrofitted fire collar protecting a 250-mm diameter High Density Polyethylene (HDPE) stack pipe

Description: The SNAP retrofitted HP250 R collar comprised a 0.95-mm steel casing with a 279 mm inner diameter and a 460-mm diameter base flange. The 184-mm high collar casing incorporated two strips of Intumescent material, 910 mm x 179 mm x 12-mm thick and 958 mm x 179 mm x 2.5-mm thick. The closing mechanism comprised five stainless steel springs, with nylon fuse links, and a 949 mm x 179-mm 304 stainless steel mesh located in between the intumescent strips as shown in drawing numbered HP 250 R-T dated 7 January 2015, by Snap Fire Systems Pty Ltd. The penetrating service comprised a 250-mm diameter High Density Polyethylene (HDPE) stack pipe, with a wall thickness of 7.25-mm fitted through the collar's sleeve. The pipe projected vertically, 2000-mm above the concrete slab. The pipe was supported at 500 mm and 1000-mm from the unexposed face of the concrete slab. On the exposed side of the slab, the penetrating pipe was supported by 5 brackets with Steel Wedge Anchors fixed to the concrete slab. On the exposed face, the pipe was capped using a Kaowool plug. On the unexposed face, the gap between the pipe and the slab was filled with a bead of Fullers Firesound as show in drawing titled "Penetration #3 – HDPE 250-mm stack", dated 13 April 2015, by Snap Fire Systems Pty Ltd.

Structural Adequacy	not applicable
Integrity	no failure at 180 minutes
Insulation	no failure at 180 minutes

and therefore for the purpose of Building Regulations in Australia, achieved a fire-resistance level (FRL) of -/180/180. The FRL is applicable for exposure to the fire from the same direction as tested.

This certificate is provided for general information only and does not comply with regulatory requirements for evidence of compliance.

Testing Officer: Mario Lara-Ledermann Date of Test: 9 February 2015

Issued on the 26<sup>th</sup> day of October 2015 without alterations or additions.

*B. Roddy*

Brett Roddy  
 Manager, Fire Testing and Assessments



This document is issued in accordance with NATA's accreditation requirements.  
 Accreditation No. 165 – Corporate Site No. 3625  
 Accredited for compliance with ISO/IEC 17025

**COPY OF CERTIFICATE OF TEST – NO. 2656**



# References

The following informative documents are referred to in this Report:

AS 1530.4-2005	Methods for fire tests on building materials, components and structures Part 4: Fire-resistance tests of elements of building construction.
AS 4072.1-2005	Components for the protection of openings in fire-resistant separating elements. Part 1: Service penetrations and control joints.
AS/NZS 1260: 2009	PVC-U pipes and fittings for drain, waste and vent application
AS/NZS 5065: 2005	Polyethylene and polypropylene pipes and fittings for drainage and sewerage applications.

#### CONTACT US

**t** 1300 363 400  
+61 3 9545 2176  
**e** [enquiries@csiro.au](mailto:enquiries@csiro.au)  
**w** [www.csiro.au](http://www.csiro.au)

#### YOUR CSIRO

Australia is founding its future on science and innovation. Its national science agency, CSIRO, is a powerhouse of ideas, technologies and skills for building prosperity, growth, health and sustainability. It serves governments, industries, business and communities across the nation.

#### FOR FURTHER INFORMATION

##### **Infrastructure Technologies**

Mario Lara-Ledermann  
Senior Fire Resistance and Assessments Engineer  
**t** +61 2 94905500  
**e** [mario.lara@csiro.au](mailto:mario.lara@csiro.au)  
**w** [www.csiro.au/Organisation-Structure/Divisions/CMSE/Infrastructure-Technologies/Fire-safety.aspx](http://www.csiro.au/Organisation-Structure/Divisions/CMSE/Infrastructure-Technologies/Fire-safety.aspx)

##### **Infrastructure Technologies**

Brett Roddy  
Team Leader, Fire Testing and Assessments  
**t** +61 2 94905449  
**e** [brett.rodny@csiro.au](mailto:brett.rodny@csiro.au)  
**w** [www.csiro.au/Organisation-Structure/Divisions/CMSE/Infrastructure-Technologies/Fire-safety.aspx](http://www.csiro.au/Organisation-Structure/Divisions/CMSE/Infrastructure-Technologies/Fire-safety.aspx)